

Allison Kershaw

From: Shannon, Matthew (MECP) [REDACTED]
Sent: February 15, 2022 10:10 AM
To: Shawn Carey
Cc: Allison Kershaw; Ritchie, John (MECP); Hetherington, Stephen (MECP)
Subject: GCC 63 watermain

Hi Shawn

I have conversed with both Aziz Ahmed and Steve Hetherington of MECP. The Ministry's position is that the watermain located on the GCC 63 property are deemed plumbing under the building code. The connected condo (CGG 73) in the south west corner does not change this position.

The Ministry will not register GCC 63 as a non-municipal year round residential drinking water system. This may be in contrast to communication you received in September 2020.

If you or Allison would like to further discuss this issue with Steve Hetherington, his number is [REDACTED]. He indicated that the Ministry's policy and guidance with regards to condo's connected to municipal drinking water systems are being updated and evolving weekly.

Regards,
Matt

Matthew Shannon
Water Inspector, Provincial Officer #1021
Owen Sound District Office
Drinking Water and Environmental Compliance Division
Ministry of the Environment, Conservation & Parks

[REDACTED] email: [REDACTED]



"We want to hear from you. How was my service? You can provide feedback at 1-888-745-8888 or ontario.ca/inspectionfeedback"

